



Clovis Fire Department

Standard # 19

PERMANENT INSTALLATION OF LPG-TANK

1. Provide a detailed site plan (8 ½" X 11") which includes tank size, location on the property and distances to the property line, street and nearby buildings.
2. "NO SMOKING WITHIN TWENTY-FIVE (25') FEET" signs shall be posted on or near the container.
3. Barrier posts are required where subject to vehicular damage. (2010 CFC 312.2). The posts shall be:
 - a) Constructed of steel not less than four inches (4") in diameter and concrete filled.
 - b) Spaced not more than four feet (4') between posts on center.
 - c) Set not less than three feet (3') deep in a concrete footing of not less than a fifteen inch (15") diameter.
 - d) Set with the top of the posts not less than three feet (3') above ground.
 - e) Located not less than three feet (3') from the tank.
4. Protection Against Tampering – When areas containing LPG system accessories, pumping equipment, that are accessible to the general public, the equipment shall be protected by means of expanded metal cage or fencing approved by the Clovis Fire Department.
5. Provide at least one (1) portable fire extinguisher rated a minimum forty (40) BC within thirty (30') feet, located by the fire department.
6. Provide an NFPA 704 placard.
7. Locate the container no closer than ten (10') feet to combustible material.
8. Containers shall be located according the 2010 CFC Table 3804.3.
9. An operational permit is required for the storage, use, or handling at normal temperature and pressure of compressed gases in excess of amounts listed in Appendix Chapter 1, Table 105.6.8.
10. An on-site Fire Department final inspection is required prior to operation.
11. L.P. Gas equipment shall be installed in accordance with the California Mechanical Code and NFPA 58. A permit from the Building Department is required for the electrical.

(Reference 2010 CFC Chapter 38)



CITY OF CLOVIS FIRE DEPARTMENT

1233 Fifth Street, Clovis, CA 93612 · (559) 324-2200



No. _____

PERMIT

Having made application in due form, the person, firm or corporation below named is hereby granted a permit to:

ISSUED TO: **Name:** _____ **Phone:** _____

Doing Business As: _____

Email Address: _____

Location of Event: _____

- Firefighter Stand By Required** (3 hr min.) \$48 per hour x # of Hours _____ = \$ _____
- Operational Permit Fee \$88**

Under the provisions of the Fire Prevention Code, the conditions and limitations of this permit are:

1. _____
2. _____
3. _____
4. _____

Permit Expiration Date: _____ **Date:** _____

This Permit Must Be Posted In A Conspicuous Place On The Premises. Non-Transferable.

By: _____
Bureau of Fire & Life Safety Prevention

NOTE: This permit may be revoked at any time the set conditions are not met or at the discretion of the Clovis Fire Department. Any ramification of a revoked permit shall be at the owner's/permittee's expense.

For Internal Use Only
\$88 Permit Fee – 62000-46337