



Clovis Fire Department

Standard #22

FLAMMABLE LIQUID LOCKERS

Storage cabinets shall be used where it is desired to keep more than 10 gallons of Class I or II liquids or more than 60 gallons of combustible liquids inside buildings. No individual container shall exceed 5 gallons capacity and not over 120 gallons shall be stored in any one cabinet. Of this total not more than 60 gallons may be Class I and Class II liquids. When approved by the Chief, three such cabinets may be located in a single fire area.

Storage cabinets shall be approved and shall be substantially constructed of 0.0478-inch steel or 1-inch plywood or equivalent. A minimum 2-inch sill shall be provided, and cabinet shall be liquid-tight to the top of the sill. Doors shall be self-closing and equipped with a latching device. Cabinets shall be painted with an approved intumescent-type fire-retardant paint. Cabinets shall be conspicuously labeled in **red** letters "**FLAMMABLE LIQUIDS**".

The following local companies are a few who carry or can obtain approved flammable liquid lockers.

Orr Safety Equipment Co. (559) 275-6529

Jorgenson & Co. (559) 268-6241

It shall in no way be assumed that the City of Clovis or the Clovis Fire Department is endorsing, supporting or recommending any specific dealer.